



Certificate of Conformity



REFU Elektronik GmbH
Marktstraße 185, 72793 Pfullingen / Germany

KoE-R-23008

Inverter Type	REFUsol 15K-2T (853P015.200) REFUsol 17K-2T (853P017.200) REFUsol 20K-2T (853P020.200) REFUsol 22K-2T (853P022.200) REFUsol 24K-2T (853P024.200)		
Use in accordance with regulations: Connection and parallel operation of power generation plants of type A and of small generation plants (maximum capacity <250 kW and nominal voltage <110 kV) Applied rules and standards: TOR Erzeuger Typ A Version 1.1:12.12.2019 OVE-Richtlinie R 25:2020-03-01			
Pfullingen	Valid from 21.12.2023		i.A. 
Location	Date	Rainer Thiele Managing Director REFU Elektronik GmbH	Kostas Kontogiannis Director Service REFU Elektronik GmbH

We reserve the right to make changes in the conformity declaration. Presently applicable edition can be obtained upon request.